



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 29/06/2025

Incharge(s): G Eswara Rao

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 26	tripped on olr	reset done	16:40:00 19:00:00 19:40:00	16:50:00 19:10:00 19:50:00	
2	CHP	scr 1 on cc 35	no drives running/error (code0071) fault showing in micro logic plc	error reset done in programming	16:00:00	16:50:00	
3	CHP	cc 117	tripped on olr	reset done	14:30:00	14:40:00	
4	CHP	cc 51	tripped on olr	reset done	20:20:00 21:00:00	20:25:00 21:05:00	
5	CHP	cc54	not healthy/EPB acted	released	14:30:00	14:40:00	
6	CHP	cc 132	PC ACTED	RESET DONE	21:00:00	21:05:00	
7	CHP	cc 44	tripped on olr in mpd	reset done	18:05:00	18:15:00	
8	CHP	scr 2 on cc34	It not taking place/pcrd tension acted	reset done	18:30:00	18:40:00	
9	CHP	scr 5 on cc32	It not taking place/M2 mpcb tripped	mpcb made on then ok	21:30:00	21:40:00	