



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 20/09/2025

Shift: B

Incharge(s): V Balaji Naik, V Balaji Naik, Saurabh Kumar Yadav, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO9	not healthy dmpr ol acted 2 times	reset done	17:30:00	17:40:00	06.30pm to 06.38pm
2	OHP	TT 4	LT not taking place,mpcb tripped	made it on	17:30:00	17:40:00	
3	OHP	TT1	LT not moving found MPCB tripped	MPCB made on	15:20:00	15:30:00	
4	CHP	CC54	Tripped on over load 4 times	Reset done	15:50:00	15:55:00	08.25pm to 08.30pm:08.35pm to 08.40pm:08.45pm to 08.50pm:09.15pm to 09.20pm
5	CHP	CC51	MPD tripped on over load 7 times and stopped feeding conveyor	Reset done	16:15:00	16:20:00	04.30pm to 04.35pm:4.40pm to 04.45pm:05.00pm to 05.05pm
6	CHP	SCR7 on CC37	LT not working found motor over load MPCB trip	Reset done	14:25:00	14:35:00	Wheel problem
7	CHP	S1 on CC111	Luffing not working found MCB trip	made on	16:10:00	16:20:00	
8	CHP	CC44	Motor over load MPD trip	reset done	18:20:00	18:25:00	
9	CHP	CC108	MPD trip on over load	Reset done	18:25:00	18:30:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 20/09/2025

Shift: B

Incharge(s): V Balaji Naik, V Balaji Naik, Saurabh Kumar Yadav, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
10	CHP	SCR3 on CC39	LT drive over load trip	Reset done	19:50:00	20:00:00	
11	CHP	SCR4 on CC31	LT not working found PCRD cable OT acted	Reset done	20:40:00	20:55:00	
12	WT	OP3	No movement found Drive 1 stator B phase cable lg cut	Lug replaced then ok , contactor add on block bypassed	20:20:00	20:32:00	No delay
13	WT	OT 1	drive1 trips in pgf1 fault	reset	19:50:00	19:55:00	
14	WT	OT1	Not working checked found Drive 1 tripprd two times on PGF 1 fault	reset done	19:50:00	19:55:00	
15	WT	AF6	Drive tripped onover current fault	Reset done	19:15:00	19:20:00	