



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 21/09/2025

Shift: B

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR on CO6a	LT not working found main power and control off	Made on	19:30:00	19:45:00	
2	OHP	VF16A	MPCB tripped due to motor tripped due to bearing struck( CHP side motor)	CHP side motor disconnected with single motor	18:36:00	19:15:00	
3	OHP	CO20	Motor protection relay acted	Reset done	18:30:00	18:40:00	
4	OHP	CO26	Electronic olr acted	Reset done	20:40:00	20:45:00	
5	CHP	S2 ON cC35	LT not working found motor 2 over load acted	Reset done	15:40:00	15:50:00	
6	CHP	SCR3 on CC39	BC frequently stopping found signal missing	after LT movement NC ok	16:20:00	16:30:00	
7	CHP	CC44	Motor MPD trip on over load	Reset done	19:05:00	19:10:00	
8	CHP	S1 on CC40	Slew not working found 30 degree limit acted	Slew limit released then ok	20:10:00	20:20:00	
9	CHP	SCR1 on CC36	Luffing down limit bypassed as per operational requirement	By passed	20:20:00	20:25:00	
10	CHP	CC21	carriage drive not working found power off condition	Made power on	17:50:00	18:05:00	
11	CHP	CC130	TIs motor tripped on over load	reset done	17:10:00	17:20:00	
12	CHP	Cc54	Motor tripped on over load 5 times	Reset done	16:20:00	17:10:00	
13	CHP	Cc51	Motot tripped on over load and stopped feeding conveyor	reset done	15:30:00	19:40:00	