



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 11/07/2025

Incharge(s): G Eswara Rao

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	brc on co 28	bw 2 not running/olr acted	reset done	22:45:00	23:00:00	
2	OHP	co 11c/s	c/s acted/return wire got cut	rejointed then reset done	00:30:00	00:45:00	
3	OHP	co 37a	zss acting/cage stuckup	zss cage replaced ok	01:40:00	02:00:00	
4	OHP	co 35	tripped on olr	reset done	03:10:00	03:20:00	
5	OHP	wobr on co 25	It not taking place in drive mode	change to DOL mode	05:15:00	05:30:00	
6	CHP	cc131	tripped on olr	reset done	04:30:00	04:35:00	
7	CHP	cc52	tripped on olr	reset done	02:10:00	02:20:00	
8	CHP	cc203	tripped on olr	reset done	22:20:00	22:30:00	
9	CHP	scr on cc38	bc zss acting/probe got damaged	bypassed for operation requirement	22:58:00	23:10:00	due to stacking mode
10	CHP	scr 10 on 105	bc not running/EPB ACTED	epb released then ok	23:25:00	23:38:00	
11	CHP	scr 5on cc32	It not taking place/pcrd tension acted	releasrd	23:46:00	00:00:00	
12	CHP	cc 112	brs acted	bypassed for operation request	00:46:00	00:58:00	
13	CHP	r1 on cc31	luffing not working/oil level low	inform to mech. and ope.	01:02:00	01:30:00	
14	CHP	cc 32	request direct mode	kept in direct mode	01:56:00	03:02:00	
15	CHP	scr 2 oncc34	It not taking place/tension acted	pcrd tension released	03:04:00	03:14:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 11/07/2025

Incharge(s): G Eswara Rao

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
16	CHP	cc 31 yard conv.	tripped on e116	reset	03:10:00	03:20:00	
17	CHP	cc 36	de c/s acted/cable got cut	re jointed then ok	03:25:00	03:45:00	
18	WT	goomty room no power	mcb 32 ams one pole got open	directed problem one	05:20:00 23:00:00	05:25:00 23:30:00	