



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/08/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|----------------------|--------------------------------|---------------------------------|----------|----------|---------|
| 1 | OHP | BRC on CO 31 | LT not taking place | M 6 tripped, reset done | 15:00:00 | 15:20:00 | |
| 2 | OHP | CO 15 | ZSS probe wire cut | joint done | 16:05:00 | 16:20:00 | |
| 3 | OHP | CO 11 Carriage drive | MPCB tripped | made on | 16:30:00 | 16:50:00 | |
| 4 | OHP | CO 35 | OLR acted | reset done | 19:30:00 | 19:35:00 | |
| 5 | OHP | CO 111 | OLR acted | reset done | 18:10:00 | 18:20:00 | |
| 6 | OHP | CO 29 | OLR acted | reset done | 20:10:00 | 20:20:00 | |
| 7 | OHP | TIS on CO 5 | TIS not running | E PB acted , released | 20:50:00 | 21:05:00 | |
| 8 | OHP | co-15 | tripped | reset done | 21:50:00 | 21:55:00 | |
| 9 | CHP | CC 40 , SCR 3 | Slew not working | jamming , informed to operation | 16:00:00 | 16:10:00 | |
| 10 | CHP | CC 24 | Carriage drive not moving | Old joint problem , rejoin done | 15:00:00 | 15:20:00 | |
| 11 | CHP | CC 51 | MPD tripped | reset | 16:10:00 | 16:15:00 | |
| 12 | CHP | CC 52 | MPD tripped | reset done | 17:55:00 | 18:00:00 | |
| 13 | CHP | CC 54 | Tripped on overload (5 times) | reset done | 17:20:00 | 21:10:00 | |
| 14 | CHP | CC 125 | OLR acted | reset done | 20:35:00 | 20:40:00 | |