



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 07/08/2025

Incharge(s): Amit Roy, K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS O0N CO-19	LB/C NOT RUNN9ING CHECKED OLR ACTED	OLR RESET	02:20:00	02:45:00	
2	OHP	CO-85	OLR ACTED	RESET	02:30:00	02:45:00	
3	OHP	CO-26	OLR ACTED(2times)	RESET	04:40:00 05:50:00	04:50:00 05:55:00	
4	OHP	CO-11 (C/D)	NOT TAKING PLACE POWER MCCB TRIP	MADE ON	02:10:00	02:22:00	
5	OHP	CC-105 SCR-7	REPORTED LT NOT TAKING PLACE CHECKED PCRD CHAIN DAMAGE	INFORM TO MECHANICAL AND PCRD CABLELOOP GIVEN AND DRUM ARREST	02:25:00	02:40:00	INFORM TO A SHIFT INC
6	CHP	CC-51	OLR ACTED (3TIMES)	RESET	01:10:00 03:40:00 04:00:00	01:20:00 04:00:00 04:10:00	
7	CHP	CC 104 SCR-9	REPORTED SLEW NOT TAKING PLACE CHECKED MPR TRIP	RESET	22:40:00	23:00:00	
8	CHP	CC-38 S-1	REPORTED SLEW NOT TAKING PLACE CHECKED MATERIAL JAMMING	INFORM TO OPERATION	22:45:00	23:15:00	
9	CHP	CC-34	OLR ACTED	RESET	00:10:00	00:20:00	
10	CHP	CC-38 S-1	LT NOT TAKING PLACE CHECKED PCRD CHAIN PROBLEM	INFORM TO MECHANICAL	23:55:00	00:20:00	
11	CHP	CC-38 S-1	Signal missing	LT forward done and tested okay	02:45:00 03:20:00	02:50:00 03:30:00	
12	CHP	CC-107	Reported not healthy	OLR acted. reset done(2times)	03:30:00 04:45:00	03:40:00 04:50:00	material overload



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 07/08/2025

Shift: C

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	CC32 SCR-5	LT not taking place	PCRD OT acted.Released and tested okay	04:25:00	04:40:00	
14	CHP	CC-34 SCR-2	LT not taking place	PCRD OT acted. Released and tested okay	05:10:00	05:20:00	
15	WT	SCO-1A(C/ D)	Reported no movement	OLR acted(2Times).Reset done	23:00:00	23:30:00	Due to track jamming
16	IOSA	NEW WOBR	Continuing from B shift	Checked and found slew moved beyond permitted angles.Slewing encoder angles bypassed in program,luffing tested okay but slew not taking place. Command is going but no movement. electrically okay	22:00:00	02:00:00	Mechanical side to be checked