



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 16/10/2025

Incharge(s): Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO-32	BC NOT RUNNING .. EM STOP WIRE CUT	RECTIFIED AND TESTED	14:40:00	15:00:00	
2	OHP	BRC ON CO-32	LT NOT WORKING .. M6 TRIPPED	RESET DONE	15:00:00	15:10:00	
3	CHP	CC-32 R-1	BC ZSS CAGE STUCK WITH COAL	MADE FREE	15:04:00	15:20:00	
4	CHP	CC-31 SCR-4	LUFF DOWN NOT WORKING	DOWN LIMIT STUCK ... RELEASED	16:10:00	16:30:00	
5	CHP	CC-35	TRIPPED ON OLR (TAIL PULLEY JAMMING)	RESET DONE	19:12:00	19:55:00	
6	CHP	CC-54	TRIPPED ON OLR	RESET DONE	14:58:00 15:50:00 16:00:00	15:05:00 15:55:00 16:05:00	
7	CHP	CC-51A	TRIPPED ON OLR	RESET DONE	20:32:00	20:40:00	