



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 10/01/2026

Incharge(s): Nagendra Midde

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 12 ZSS	PROBE GOT CUT	REJOINT	07:20:00	07:30:00	
2	CHP	CC 114	OLR ACTED	RESET	07:20:00	07:20:00	
3	CHP	CC 51	FEEDING CONV MPD ACTED	RESET	11:55:00	13:40:00	3 TIMES
4	CHP	SCR 6 ON CC 39	LT M2 TRIPPED	MADE IT ON	12:50:00	13:00:00	
5	CHP	SC R6 ON CC 39 B/C	OLR ACTED	RESET	13:30:00	13:40:00	
6	CHP	CC 131 HEALTHY STOPPING	AUXILLARY CONTACK BLOCK LOOSE	TIGHTENED	11:00:00	11:15:00	
7	WT	OT2	D2 TRIPPED ON PGF1	RESET	08:00:00 09:30:00	08:05:00 09:35:00	
8	WT	OT4	CLAMP LIMIT SWITCHES HIGH MISSING DUE TO CORE PROBLEM	SPARE CORE CONNECTED THEN OK	13:45:00	13:55:00	