



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 04/02/2026

Area: WT

Equipment	Job
OT 3	M2 ,burnt motor coupling removed and sent to E R S
OP 5	Track lifting done by railways @ parking zone
CP 3 jobs	Control Desk side wiring done ,trolly line inspection done from C D found signals OK
CP 1,2 and 4	After rake maintenance done
OP 1,4,5 and 8	After rake maintenance done