



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 10/01/2026

Area: OHP

Equipment	Job
brc -4 on co-28	B/w-1 zss probe fixing plate was welded and restored both B/W ZSS in circuit.