



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 29/01/2026

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS on co 21	LT not working	wrong complaint	15:00:00	15:10:00	
2	OHP	BRC on CO 8A	bc not running, Emergency PB acted	released	20:45:00	20:59:00	
3	OHP	BRC on CO 28	B/W-1 and 2 not running, charge pressure problem	informed mechanical	16:16:00	16:29:00	
4	OHP	WOBR on CO 29	slew not working, drive tripped	reset	21:30:00	21:45:00	
5	CHP	CC 117	motor tripped in olr	reset	15:40:00	15:50:00	
6	CHP	CC 54	motor tripped 4 times	reset	19:20:00	19:40:00	
7	CHP	CC 51	mpd tripped 3 times	reset	15:25:00	15:30:00	
8	WT	OP 5	no movement, d5 OLR acted	reset	17:00:00	17:10:00	