



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 09/06/2025

Area: CHP

Equipment	Job
CC 31,38,49,50,R 1,SCR 3	Running inspection was done
CC 222,223 gallery	Lighting ckt problem rectified and improved lighting
CCR	Micro logic PLC replaced to resolve communication issue
CC 15,26A, 36,37,SCR 1	PPM was done