



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/04/2025

Shift: A

Incharge(s): V Balaji Naik

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TIS ON CO 29	ZSS SIGNAL NOT COMMING IN PROBE	CHECKED & FOUND; SIGNAL IS OK/KEPT IN CKT.	06:30:00	06:45:00	
2	OHP	CO 8A	brs not working/ receiver&trasmitter; tightend.	reset done	06:30:00	07:00:00	
3	OHP	brc on co 8a	It not taking plac/ pcrd cable tension acted due guide stuckup	informed to operation & mech; tension released temporary	09:00:00	09:20:00	
4	OHP	brc on co 31	bc not running/olr acted	reset done	13:00:00	13:20:00	
5	OHP	brc on co 34	It not taking place/pcrd cable tension acted due to guide problem	tension released & inform; to operation	09:00:00	09:20:00	
6	CHP	scr 5 on cc32	bc not running/signal problem	checking is going on	10:30:00	10:40:00	
7	CHP	scr 2on cc 34	bc frequently stopping/signalmissing	checking is going on by g shift	08:00:00	08:25:00	
8	WT	op 4	forward /reverse not taking place/acb tripped at lc 2b due d6 winding lead cut	d6 coil connection discnected and acb made on then tested ok	11:45:00	12:00:00	
9	WT	op 10	communication problem	modem power recycled then ok	06:00:00	06:10:00	