



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 09/01/2026

Area: OHP

Equipment	Job
co-44 h/e hoist	Motor and brake unit is removed.
Hoists brake	LOSP-2 VS level Hoists Supply checking is done. CO-13a,14a,41a h/e hoists.
co-16a Field devices	PPM is done, and one pull chord switch bypassed and restored in circuit.
JH-2 to JH-3	LDB's ppm is done lighting circuit rectification is done
co-7 pullchord	pull chord reset done and t/e 6 no.'s circuit rectified and kept in circuit.
brc-2 on repair bay	HT transformer ppm and termination is checked. Slip maintenance is done.
brc-1 on co-31	HT slip ring maintenance is done
wbr-3 on co-29	bucket wheel motors base bolts tightness is done.
Mixer building area	House keeping is done
co-30,31,32,8a,31a,32a	Chute Vibrators Inspection is done
co-28	field devices ppm is done
Lighting timers	All PLC lighting timers ON duration have been adjusted
brc-4 on co-28	oil level switch and suction line switch, checked and restored in circuit. nitrogen is filled and restored acc2 also in circuit. Oil level Switch Common High Fault found, direct termination is done and trail run is taken.