



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 19/01/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WBR ON CO 26	SLEW DRIVE TRIPPED	RESET	23:55:00	00:05:00	
2	OHP	CO 26	OLR ACTED	RESET	00:00:00 02:10:00	00:10:00 02:20:00	
3	OHP	CO 29	OLR ACTED	RESET	00:00:00	00:10:00	
4	OHP	BRC ON CO 33M B/C	OLR ACTED DUE TO JAMMING	RESET	01:00:00	01:15:00	
5	OHP	CO 113	OLR ACTED	RESET	04:50:00	05:00:00	
6	OHP	TBS ON CO 20 LT	DRIVE TRIPPED	RESET	03:50:00	04:05:00	
7	OHP	WBR ON CO 6A B/W	HYDRAULIC PUMP CONTROL MCB IS IN OFF CONDITION	MADE IT ON	02:40:00	02:50:00	
8	CHP	CC 32	OLR ACTED	RESET	23:25:00	23:30:00	
9	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	23:10:00	05:30:00	7 TIMES
10	CHP	CC 14	CONTROL MCB TRIPPING DUE TO EARTH FAULT IN C/S MODULE	REPLACED	22:30:00	22:50:00	