



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 27/10/2025

Incharge(s): Amit Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR on CO-29	B/C not running	OLR acted.Reset done	07:30:00	07:45:00	
2	OHP	TBS on CO-19	Left luff not working	OLR acted.Reset done	06:15:00	06:30:00	
3	OHP	WOBR on CO-26	B/C not running	Found material jamming	08:25:00	09:00:00	Informed to operation
4	OHP	CO-58	Reported tripped	MPCB tripped due to overload.Made on	13:00:00	13:25:00	
5	OHP	CO-25	Reported tripped	OLR acted.Reset done	13:30:00	13:40:00	
6	OHP	CO-10A	Reported tripped	OLR acted.Reset done	11:45:00	11:55:00	
7	CHP	Cc-31	Reported tripped	OLR acted.Reset done	06:50:00	06:55:00	
8	CHP	CC-38 SCR-6	B/C not running	OLR acted.Reset done	07:21:00	07:26:00	
9	CHP	CC-35 Scr-3	Reported luff and LT not taking place	Luff was working fine.LT drive tripped.Reset done	08:20:00	08:35:00	
10	CHP	Cc112	B/C not running	Discharge chute jamming found	08:30:00	08:45:00	Informed to operation
11	CHP	CC-112 SCR-8	Reported signal problem	Power recycled and LT moved and tested okay	10:30:00	11:00:00	
12	CHP	Cc-54	Reported tripped	OLR acted.Reset done(4times)	06:30:00	13:30:00	
13	CHP	Cc-53	Reported tripped	MCCB tripped due to overload(2times)	08:40:00	09:40:00	
14	CHP	Cc-58	Reported tripped	MPD tripped.Reset done	07:50:00	08:00:00	
15	CHP	Cc-51	Feeding conveyor stopped	MPD tripped.Reset done	06:00:00	06:30:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 27/10/2025

Incharge(s): Amit Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
16	WT	OT-2	Encoder removed in C-shift due to mechanical problem	Endocer fixing done	09:00:00	10:30:00	no delay
17	IOSA	TBS	LT not working	PCRD chain problem.	09:00:00	09:45:00	Informed to mechanical