



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 01/08/2025

Shift: B

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO 28	BC not running	OLR acted	16:50:00	17:00:00	
2	OHP	TBS on CO 22	Main braker tripped due to E PB acted	E PB released and braker made on	18:15:00	18:30:00	
3	OHP	WOBR on CO 26	LT limit acted . Also no control	LT limit bypassed and again kept in circuit. Control fuse 32A blown , loop given . Then healthy	20:00:00	21:00:00	
4	OHP	CO 26	OLR acted	reset done	21:10:00	21:20:00	
5	CHP	CC 34 , SCR 2	Luff not working	wrong complaint	15:30:00	15:40:00	
6	CHP	CC 105 SCR 7	Slew not working	charge pressure alarm , spider reset	17:10:00	17:25:00	
7	CHP	CC 105, SCR 7	LT not working	ot ACTED , RELEASED	21:05:00	21:10:00	
8	CHP	cc 32, scr 5	BC not running	OLR acted , reset done	20:10:00	20:20:00	
9	CHP	CC 34	Yard conveyor overload acted	reset done	20:55:00	21:05:00	
10	CHP	CC 112 , SCR 8	BW slew not working	oil level low. informed to mechanical	21:25:00	21:35:00	
11	CHP	CC 105, SCR 7	BC signal missing	LT done , then ok	21:10:00	21:25:00	
12	CHP	CC 51	OLR acted ( 5 times)	reset done	18:40:00	21:10:00	
13	CHP	CC 114	OLR acted	reset done	17:10:00	17:20:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 01/08/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC 54	OLR acted	reset done	16:00:00	16:15:00	
15	WT	CT 1	Not rotating	CAM switch not healthy , cleaning then okay	18:00:00	18:15:00	
16	WT	OC 1A	Not healthy showing On feedback in Red	OLR acted in panel , reset done	19:00:00	19:15:00	
17	IOSA	OC 37A	OLR acted	reset done	14:55:00 16:30:00	15:15:00 16:50:00	
18	IOSA	L and T WOBR	LT not working due to pcrd overtension acted	released, then okay	20:50:00	21:00:00	