



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 31/01/2026

Incharge(s): Amit Roy

Shift: C

| Sl No | Area | Equipment     | Problem                             | Action                                       | From     | To       | Remarks |
|-------|------|---------------|-------------------------------------|--|----------|----------|---------|
| 1     | OHP  | WOBR on CO-29 | Reported no operations taking place | MCB tripped in PLC panel.Made on             | 22:30:00 | 22:40:00 |         |
| 2     | OHP  | WOBR on CO-29 | Reported no operations taking place | Down limit acted.Boom lifted and tested okay | 03:40:00 | 03:50:00 |         |
| 3     | OHP  | WOBR on CO-29 | Reported LT not taking place        | PCRD tension acted.Released and tested okay  | 04:00:00 | 04:10:00 |         |
| 4     | OHP  | CO-25         | Reported tripped                    | OLR acted.Reset done                         | 00:30:00 | 00:40:00 |         |
| 5     | CHP  | CC-28         | Reported tripped                    | OLR acted.Reset done(2 times)                | 23:15:00 | 02:15:00 |         |
| 6     | CHP  | CC-29         | Reported tripped                    | OLR acted.Reset done(2 times)                | 04:10:00 | 05:25:00 |         |
| 7     | CHP  | CC-125        | Reported tripped                    | OLR acted.Reset done                         | 23:55:00 | 00:05:00 |         |
| 8     | CHP  | CC-54         | Reported tripped                    | OLR acted.Reset done(3 times)                | 00:15:00 | 05:30:00 |         |
| 9     | CHP  | CC-51         | MPD tripped                         | Reset done                                   | 05:00:00 | 05:10:00 |         |
| 10    | CHP  | CC-131        | Reported tripped                    | OLR acted.Reset done(3 times)                | 23:30:00 | 03:30:00 |         |
| 11    | CHP  | CC-51A        | ZSS acting                          | Cage stuck.Cage replaced and tested okay     | 00:10:00 | 00:40:00 |         |