



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 13/01/2026

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO33 m	yard interlock not coming,zss cage module loose connection,IN CJD TB all wrong wiring	zss bypassed given clearance @8pm than stream stopped zss kept in CKT,CJD bypassed,all cable removed	19:40:00	21:00:00	
2	OHP	BRC on CO28	CT not working,drive tripped	reset	21:10:00	21:30:00	
3	CHP	CC 28	tripped in olr	reset	17:30:00	17:35:00	
4	CHP	CC 51	mpd tripped 2 times	reset	15:55:00	16:00:00	
5	CHP	CC 108	olr acted	reset	19:35:00	19:40:00	
6	CHP	CC 112,cc105	i/c tripped in LC2	made it on	14:30:00	15:00:00	
7	WT	OT 1	D1 tripped in pgf1 fault brake problem	informed mechanical,reset	18:35:00	18:40:00	
8	WT	OT 2	d2 tripped 2 times pgf1 fault	reset	18:00:00	18:05:00	