



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 11/11/2025

Area: WT

Equipment	Job
MIS	Damaged coupling of pusher motor removed and fixed spare coupling
LC 2A	Antenna with modem, antenna cable ,PLC replaced and PLC replaced in LC 1 also
OP 1	Trolley line inspection done, parking area section found uneven, rectified
OP 2	After rake maintenance done