



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/06/2025

Incharge(s): Arnab Roy

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------|---|---|----------|----------|------------|
| 1 | OHP | CO 29 | OLR acted | reset done | 07:45:00 | 07:55:00 | |
| 2 | OHP | CO 87 | DMPR shows in overload (2 times) | reset done | 09:00:00 | 09:35:00 | |
| 3 | OHP | CO 5 | BRS in bypass condition | Kept in circuit after operation clearance | 07:30:00 | 07:45:00 | |
| 4 | CHP | CC 44 | BRS to be bypassed as per operation request | Bypass done | 08:50:00 | 09:00:00 | In IO rack |
| 5 | CHP | CC 125 | OLR acted (3 times) | reset done | 10:30:00 | 10:40:00 | |
| 6 | CHP | CC 44 | OLR acted | reset done | 10:50:00 | 10:55:00 | |
| 7 | CHP | CC 34 | Material selection to be bypassed | Bypass done | 12:36:00 | 12:38:00 | |
| 8 | CHP | CC 54 | Tripped in overload | reset done | 12:10:00 | 12:25:00 | |
| 9 | WT | OP 8 | Motor 4 tripped | reset done | 12:20:00 | 12:30:00 | |