



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 12/07/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 9	Thermal OLR acted (3 times)	reset done	14:30:00 20:00:00	14:46:00 22:00:00	motor temp 85 degree .. power and control made off and asked operation to change the stream ... physical checked return side cutting stringer post and idlers not rotating near 150
2	OHP	CO 87	OLR acted	reset done	15:10:00 15:30:00	15:15:00 15:45:00	
3	OHP	WOBR on CO 6A	BC not running due to BSS acted , belt off centering	BSS reset	15:50:00	16:05:00	
4	OHP	CO 65	CJD not working due to feedback wire opened at module	feedback wire connected properly	14:15:00	14:30:00	
5	OHP	WOBR on CO 25	LT not working due to M-1 tripped in Drive mode	kept in DOL mode and given clearance	17:30:00	17:45:00	
6	OHP	CO 26	OLR acted	reset done	21:20:00	21:30:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 12/07/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
7	CHP	CC 29	Chute sensor acted	Cleaned and given clearance	14:30:00	14:40:00	
8	CHP	CC 32 , SCR 5	BC zero speed cage problem	Cage lifted and zero speed bypassed	17:00:00	17:20:00	cage changing going on after machine stopped, also informed to C shift
9	CHP	CC 105 , SCR 10	BC stopping	ZSS cage stucked , adjusted	15:30:00	16:00:00	
10	CHP	CC 125	OLR acted (2 times)	reset done	17:30:00	18:20:00	
11	CHP	CC 31 , R-1	Slew not working	Drive tripped, reset done	18:20:00	18:35:00	
12	CHP	CC 32 , SCR 5	BC stopping frequently	Checked, no electrical problem found	14:47:00	15:10:00	
13	CHP	CC 113A	Tripped on overload	reset done	15:00:00	15:10:00	
14	CHP	CC 131	Tripped on overload	reset done	20:40:00	20:45:00	
15	WT	CO 2	MPCB tripped (2 times)	reset	15:45:00	16:25:00	
16	WT	CO 3	Not moving	Chceked , in B phase lug got cut in motor terminal box . Connected and clearance given	17:30:00	17:55:00	
17	WT	SCO 1A	OLR acted	reset done	16:50:00	16:55:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 12/07/2025

Shift: B

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
18	WT	OT1	Not moving due to outhaul side reverse limit not closing properly	Limit adjusted properly , then ok	17:35:00	17:50:00	