



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 05/09/2025

Incharge(s): K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-13(B/D)	MPCB TRIP DUE MATERIAL JAMMING	AFTER CLEAN MATERIAL THAN RESET DONE	17:30:00	17:40:00	
2	OHP	CO-9	OLR ACTED	RESET DONE	18:20:00	18:25:00	
3	OHP	CO-35	OLR ACTED	RESET DONE	19:30:00	19:40:00	
4	OHP	CO-29	OLR ACTED	RESET DONE	20:00:00	20:10:00	
5	OHP	CO-67	OLR ACTED	OLR RESET DONE	21:30:00	21:45:00	
6	OHP	CC-31	OLR ACTED	OLR RESET DONE	21:54:00	21:56:00	
7	CHP	CC-29 TT	REPORTED SHOW DOUBLE INDICATION CC-111AND CC-32	CC-111 INDICATION REMOVED THAN OK	16:00:00	16:10:00	
8	CHP	CC-37 SCR-7	LT NOT TAKING PLACE CHECKED MPCB 5AND 6 TRIPPED DUE TO TRACK JAMMING	AFTER TRACK JAMMING CLEAR MPCB RESET DONE THAN OK	14:50:00	15:50:00	
9	CHP	CC-40 SCR-3	LUFFING DOWN NOT WORKING CHECKED FILTER CLOGGED 3 BIT AND K-31 RELAY CHATERING	RECTIFIED THAN OK	16:15:00	16:40:00	
10	CHP	CC-105 SCR-10	B/W MCCB TRIP	MCCB MADE ON THAN OK	18:00:00 20:40:00	18:10:00 20:50:00	B/W POWER CABLE TO BE CHECKED IN G SHIFT
11	CHP	CC-31SCR-4	B/C OLR TRIPPED	OLR RESET DONE	19:00:00	19:15:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 05/09/2025

Incharge(s): K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	CHP	CC-54	OLR ACTED(2TIMES)	OLR RESET DONE	16:55:00 17:20:00	17:00:00 17:25:00	
13	WT	OP-4	NOT MOVE CHECKED AND FOUND D-3 OLR ACTED	OLR RESET DONE	14:30:00	14:45:00	
14	WT	CP-3	NOT MOVED CHECKED AND FOUND D-3 OLR AND D-5 , 2 LUGS CUT	D-3 OLR RESET DONE AND D-5 RE LUGGING AND TERMATION AND TESTING WAS DONE	17:30:00	18:25:00	