



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 19/06/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR ON CO 8A	B/C OLR ACTED	RESET	07:30:00	07:40:00	
2	OHP	CO 29	OLR ACTED(2TIMES)	RESET	06:20:00	06:50:00	
3	OHP	CO 34	OLR ACTED	RESET	08:40:00	08:50:00	
4	OHP	VF 14	M2 MPCB TRIP	RESET	07:00:00	07:15:00	
5	OHP	CO 5	STOPPING ON ZSS ,MOTOR TB B PHASE LUG GOT CUT	RE LUGGING AND TERMINATION WAS DONE THAN OK	10:15:00	11:30:00	
6	CHP	CC 33 scr 4	slew not working,fault reset not reset by operator	fault reset done in operator cabin	06:15:00	06:30:00	
7	CHP	CC 39 scr7	slew not working,brake failed alarm	reset	06:15:00	06:35:00	
8	CHP	CC 104,scr9	operator fan not running,mcb is in off	mcb made on	06:35:00	06:50:00	
9	CHP	CC 131	olr acted	reset	10:10:00	10:15:00	2 times
10	CHP	CC 105 SCR 10	all drive not working,EB03 fault in PLC,lower house upper house PLC communication brake	OFC cable got cut near slew chamber	08:45:00	09:30:00	to be checked in G shift
11	CHP	CC 40 SCR6	BC and BW both MPR tripped in phase unbalance fault	reset it done	10:45:00	11:00:00	inform G shift
12	CHP	cc 38 SCR 3	slew not taking place	wrong complaint	11:10:00	11:15:00	
13	IOSA	stacking stream	communication fault,loose connection from GEB to OFC LIU	properly connected	10:10:00	10:25:00	