



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 24/01/2026

Shift: B

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 25	OLR ACTED	RESET	18:00:00	20:20:00	4 TIMES
2	OHP	CO 26	OLR ACTED	RESET	20:00:00	20:10:00	
3	OHP	WBR ON CO 6A LT	SELECTOR SWITCH IN LOCAL MODE	CHANGED TO REMOTE	19:20:00	19:35:00	
4	OHP	CO 33M	OLR ACTED	RESET	21:30:00	21:35:00	
5	CHP	CC 28	OLR ACTED	RESET	21:20:00	21:25:00	
6	CHP	SCR 7 ON CC 37 SLEW	BREAK FAIL ALARM ACTED	RESET	14:25:00	14:35:00	
7	CHP	CC 54	OLR ACTED	RESET	15:30:00	15:40:00	
8	CHP	CC 51	OLR ACTED	RESET	19:00:00	19:05:00	
9	CHP	CC 51	FEEDING CONV MPD ACTED	RESET	20:40:00	21:45:00	4 TIMES
10	CHP	CC 116 BRS NOT R ESETTING	RESET	THEN OK	20:05:00	20:20:00	
11	WT	OP6	DRIVE 5 TRIPPED	RESET	19:30:00	19:45:00	