



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 20/06/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 35	OLR ACTED	RESET	08:10:00	08:15:00	
2	OHP	CC 54	OLR ACTED (2TIMES)	RESET	06:50:00	07:20:00	
3	CHP	CC 131	OLR ACTED (2TIMES)	RESET	12:25:00	13:05:00	
4	CHP	CC 51	OLR ACTED	RESET	12:10:00	12:20:00	
5	CHP	CC 111 S 3	B/C NOT RUNNING MAIN CONTACTOR COIL BURN	NEW 3TF50 CONTACTOR FIXED	06:45:00	07:50:00	
6	CHP	CC 33 SCR 4	LT NOT TAKING PLACE PCRD GUIDE PROBLEM	INFORMED MECH ,proper winding done	08:15:00	08:50:00	
7	CHP	CC 39 scr7	LT not working,OT acted	OT released	09:35:00	10:00:00	
8	CHP	CC 32 SCR 5	LT not working,mpcb 2 tripped frequently	made it on	09:50:00	13:30:00	8 times
9	CHP	CC 31 R1	slew not working,,mechanical tyre coupling damaged	checked electrical side all ok,informed mech	10:25:00	10:45:00	