



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 26/05/2025

Area: WT

Equipment	Job
OP 10	D4 motor checked found winding OPEN,kept in bypass (power kept OFF in drive panel)
OP 10	D4, motor bed bolts found loose and misalignment ,realignment bolts fixing done
OP 9	Went to Non-Power zone,Brought to Parking zone,Forward limit 1 kept in bypass