



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 29/08/2025

Area: CHP

Equipment	Job
SCR 6,7	Slew and Luff instrumentation switches cleaned and covered
SCR 5	LUFF oil level ckt problem rectified and kept in ckt
RG EOT	PPM was done
SCR 1	Boom position kept in ckt
JH 210	Lighting improved by providing 5 nos 30W LED lamps
SCR 10	Bucket wheel main pump ckt problem rectified, Boom ZSS kept in ckt
SCR 2	Stacking angle increased as per operation requirement
CC 37	TUL chute sensor modification done