



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/10/2025

Shift: B

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WBR ON CO 26 SLEW	DRIVE TRIPPED	RESET	14:40:00	14:55:00	
2	OHP	BRC ON CO 34 B/W 2	OLR ACTED	RESET	15:00:00	15:15:00	
3	OHP	CO 29	OLR ACTED	RESET	17:30:00	17:40:00	
4	OHP	CR1A	MOTOR PROTECTION RELAY TRIPPED	RESET	16:10:00	16:20:00	
5	CHP	CC 28	OLR ACTED	RESET	14:30:00 17:30:00	14:40:00 17:40:00	
6	CHP	CC 22 CD	OLR ACTED	RESET	19:00:00	19:10:00	
7	CHP	CC 108	OLR ACTED	RESET	15:00:00	15:05:00	
8	CHP	SCR 5 ONJ CC 33 LT	DRIVE TRIPPED	RESET	17:00:00	17:30:00	
9	CHP	SCR 5 ON CC 33 LT	SPEED REFERENCE LOOSE IN DRIVE TERMINALS	TIGHTENED	18:30:00	18:50:00	
10	CHP	R1 ON CC 32	B/C ZSS INTERLOCK CAGE STUCK WITH COAL PIECE	REMOVED	19:10:00	19:30:00	
11	CHP	SCR 6 ON CC 38	LT DRIVE TRIPPED	RESET	20:40:00	20:50:00	
12	WT	OT1	DRIVE TRIP ON PGF1 FAULT	RESET	14:05:00 14:20:00	14:10:00 14:25:00	
13	WT	OP1	DRIVE1 OLR ACTED	RESET	18:00:00	18:15:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/10/2025

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	WT	OT3	DRIVE 1 ENCODER FAULT	RESET	19:00:00	19:05:00	