



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/10/2025

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	Co 49	not healthy,BRS acted,fuse blown in control jb	fuse replaced	00:30:00	01:00:00	
2	OHP	BRC on CO 33M	Lt problem,OT acted	OT released,LOOP given drum arrested	02:30:00	02:45:00	guide problem
3	OHP	CO 35	OLr acted	reset	04:20:00	04:25:00	
4	OHP	BRC on CO 32	b/c olr acted due to jamming	reset	02:30:00	02:45:00	
5	CHP	CC 39	olr acted	reset	01:36:00	01:42:00	
6	CHP	CC 33	olr acted	reset	02:50:00	02:55:00	
7	CHP	CC 33 scr5	cjd of TUL acted,jamming is there	tul cjd ok	03:15:00	03:25:00	
8	CHP	CC 33 SCR5	Lt not working,wrong complaint	all found ok	03:25:00	03:35:00	
9	CHP	CC 38 SCR 6	slew not working, jamming	informed operation than healthy	04:40:00	04:51:00	
10	CHP	CC 32 R1	BC not working,zss cage stucked by stone	cage made free	05:18:00	05:28:00	
11	CHP	CC 112 SCR 8	luffing not working,oil level low	informed mechanical	05:20:00	05:30:00	
12	CHP	CC 23	ZSS acted, stone stucked in cage	stone removed	01:00:00	01:10:00	
13	CHP	CC 109	pcs acted	reset	00:05:00	00:15:00	
14	CHP	CC 29	cjd acted due to jamming	reset	00:10:00	00:20:00	
15	CHP	CC 29 TT	flap gate tripped	reset	01:05:00	01:15:00	
16	CHP	CC 45	olr acted	reset	05:40:00	05:45:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/10/2025

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
17	CHP	CC 51	mpd tripped on overload stop feeding conveyor	reset	23:00:00	03:00:00	
18	WT	CO 3(B)	olr acted	reset	04:00:00	04:05:00	3 times