



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 12/05/2025

Area: CHP

Equipment	Job
JH3 HOIST	GRAVITY LIMIT SWITCH REPLACED
CC 13, CC17, CC24	PPM DONE
CCC 54	MOTOR REPLACED AND ALIGNMENT DONE
SCR 8	6 NOS 35 LED FIXERS REPLACED, LUFF DOWN LIMIT STRIKER WELDED AND TESTED. UPS PANEL REMOVED.
R1 , S3, SCR8	SHIFTED TO CC 31, CC111, CC112 RESPECTIVELY