



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 25/08/2025

Area: OHP

Equipment	Job
tbs-24	flash over took place in coupler, 2 fuses blown , dnw are on job,
brc-3	shifted from co-32 to co-8a
tbs-20	cjd and boom run indication is restored to normal.