



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 07/01/2026

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	brc on co-31	B/C TRIPPED ON OLR	RESET DONE	06:50:00	07:05:00	
2	OHP	CO-34	OLR ACTED	RESET DONE	09:00:00	09:10:00	
3	OHP	CO-34	REPORTED C/S ACTED	SENSOR CLEANED THAN RESET DONE OK	09:15:00	09:30:00	
4	OHP	BRC ON CO-28	REPORTED B/W S NOT RUNNING	FAULT RESET IN OPERATOR CABIN THAN OK	09:35:00	09:50:00	
5	OHP	CO-29	OLR ACTE4D	RESET DONE	09:45:00	09:50:00	
6	CHP	CC-26	TRIPPED ON OLR	RESET DONE	06:33:00	06:40:00	
7	CHP	TT ON CC-28	REPORTED LT NOT TAKING PLACE MPCB TRIP	MADE ON THAN OK	11:00:00	11:10:00	
8	CHP	CC-131	OLR ACTED (2TIMES)	RESET DONE	11:30:00 13:10:00	11:35:00 13:15:00	
9	CHP	CC-51	MPD ACTED (20 TIMES)FEEDING CONVEYOR STOPPED	RESET DONE	06:50:00	13:15:00	
10	CHP	CC-34 SCR-1	REPORTED B/W NOT RUNNING	WRONG COMPLAINT	07:50:00	08:00:00	
11	IOSA	BRC ON OC-15A	REPORTED LT NOT TAKING PLACE FOUND SKEW LIMIT DAMAGED	SKEW ADJUSTED LIMIT BYPASSED	08:30:00	09:45:00	