



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/05/2025

Shift: C

Incharge(s): G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 25	Overload acted	reset done	22:10:00	22:20:00	
2	OHP	WOBR on CO 29	LT not taking place	M - 4 tripped due to track jamming. Reset done , informed to operation	22:30:00	22:45:00	
3	OHP	CO 33M	Overload acted	reset done	22:50:00	23:00:00	
4	OHP	CO 29	Stopped in ZSS	ZSS probe wire got cut near neck. Probe replaced	23:20:00	23:45:00	
5	OHP	WOBR on CO 25	BC stopping in ZSS	ZSS wire got cut . Joint done	01:50:00	02:15:00	
6	OHP	TBS on CO 20	Right Luff not working	Brakes not releasing properly mechanically . Informed to mechanical	04:30:00	05:00:00	
7	OHP	VS 4A	Tripped in overload	reset done	04:30:00	04:40:00	
8	OHP	WOBR on CO 25	LT not working	PCRD overtension acted , released	05:30:00	05:45:00	
9	CHP	CC 34, SCR 2	BW not running	Drive reset	00:35:00	00:55:00	
10	CHP	CC 33, SCR 4	LT not working	PCRD overtension limit acted , released	01:00:00	01:15:00	
11	CHP	CC 40 , SCR 6	LT not working	M-2 MPCB tripped. Made on , also coal jamming on GVM side track. Informed to operation	01:20:00	01:30:00	
12	CHP	CC 34 , SCR 2	LT not working	PCRD overtension limit acted . Released, then ok	04:00:00	04:10:00	
13	CHP	CC 44	Tripped in overload	reset done	04:55:00	05:00:00	



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/05/2025

Incharge(s): G Eswara Rao

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC 54	Tripped in overload	reset done	04:30:00 23:15:00	04:40:00 23:25:00	
15	CHP	CC 132	Tripped in overload	reset done	22:15:00	22:30:00	
16	IOSA	FLS wobr	LT not working	PCRD overtension acted . Released , then ok	00:10:00	00:20:00	