



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 21/11/2025

Shift: B

Incharge(s): Nagendra Midde

| Sl No | Area | Equipment                  | Problem                      | Action          | From                 | To                   | Remarks |
|-------|------|----------------------------|------------------------------|-----------------|----------------------|----------------------|---------|
| 1     | OHP  | TBS ON CO 5A LT            | M1, M2 OLR ACTED             | RESET           | 18:35:00             | 18:45:00             |         |
| 2     | OHP  | CO 85                      | OLR ACTED                    | RESET           | 19:20:00             | 20:20:00             | 3 TIMES |
| 3     | OHP  | TBS ON CO 7A RIGHT LUFF UP | LIMIT TIED                   | REMOVED THEN OK | 19:45:00             | 20:00:00             |         |
| 4     | OHP  | CO 25                      | OLR ACTED                    | RESET           | 19:45:00             | 19:55:00             |         |
| 5     | OHP  | BRC ON CO 30               | B/C OLR ACTED DUE TO JAMMING | RESET           | 20:40:00             | 20:50:00             |         |
| 6     | OHP  | TT4 F/G                    | OLR ACTED                    | RESET           | 18:00:00             | 18:10:00             |         |
| 7     | OHP  | RSCO 6A CD                 | OLR ACTED                    | RESET           | 14:05:00             | 14:15:00             |         |
| 8     | CHP  | CC 51                      | FEEDING CON OLR ACTED        | RESET           | 16:30:00             | 20:30:00             |         |
| 9     | CHP  | CC 51                      | OLR ACTED                    | RESET           | 16:30:00<br>20:20:00 | 16:35:00<br>20:25:00 |         |
| 10    | CHP  | CC 52                      | FEEDING CONVEYOR OLR ACTED   | RESET           | 17:30:00<br>18:50:00 | 17:35:00<br>18:55:00 | 2 TIMES |
| 11    | CHP  | CC 54                      | OLR ACTED                    | RESET           | 20:25:00<br>21:05:00 | 20:30:00<br>21:10:00 |         |
| 12    | CHP  | CO 26                      | OLR ACTED                    | RESET           | 17:40:00             | 17:50:00             |         |
| 13    | CHP  | CC 47                      | DRIVE TRIPPED                | RESET           | 18:30:00             | 18:40:00             |         |



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 21/11/2025

Incharge(s): Nagendra Midde

Shift: B

| Sl No | Area | Equipment            | Problem                          | Action          | From     | To       | Remarks |
|-------|------|----------------------|----------------------------------|-----------------|----------|----------|---------|
| 14    | CHP  | SCR 6 ON<br>CC 38 LT | DRIVE FAULT                      | RESET           | 19:55:00 | 20:10:00 |         |
| 15    | WT   | OC 1A                | OLR ACTED                        | RESET           | 16:30:00 | 16:40:00 |         |
| 16    | WT   | OT3                  | DRIVE 1 TRIPPED ON ENCODER FAULT | RESET           | 16:00:00 | 16:10:00 |         |
| 17    | WT   | CO 3                 | OLR ACTED DUE TO JAMMING         | RESET           | 21:00:00 | 21:10:00 |         |
| 18    | IOSA | OC 7B                | ZSS CAGE STUCK WITH COAL PIECE   | REMOVED THEN OK | 20:45:00 | 21:05:00 |         |