



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 26/12/2025

Area: CHP

Equipment	Job
CC 49	Motor replaced, Shaft to shaft alignment done and trail run was taken
SCR 3,R 1	Yard machines interchanged
JH C 5,15,16,CC 103DE	Hoist panels maintenance was done
LC 15,16,21	6 nos tube fixtures replaced
CC 21	PPM was done