



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/05/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO 33M	pending from C shift,oil temp high	operator cabin fault reset	06:30:00	07:00:00	
2	OHP	CO 21	C shift pending problem,Zss bypassed in module,control cable loose connection	110 V control cable tightened,kept in ckt	07:00:00	07:15:00	
3	OHP	TBS on CO 20	LT not taking place,OT acted	OT released	08:00:00	08:15:00	
4	CHP	CC 32	tripped in OLR	reset it done	06:16:00	06:21:00	
5	CHP	CC 32 SCR 5	BC not running olr acted,due to jamming,and belt off centering	olr reset and informed operation and mech	08:05:00	08:10:00	
6	CHP	CC 33 scr 4	slew not working,	wrong complaint	09:26:00	09:38:00	
7	CHP	CC 35 SCR 2	LT not working,OT acted	OT released	12:25:00	12:40:00	
8	CHP	CC 54	OLr acted	reset it done	11:00:00	11:10:00	
9	CHP	CC 131	OLR acted	reset it done	10:50:00	11:00:00	
10	WT	CP 1	no movement,PLC is in stop mode	PLC power recycle done than ok	06:45:00	06:55:00	