



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 15/07/2025

Shift: B

Incharge(s): V Balaji Naik

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO34	No power found ACB in off condition	made on then ok	16:10:00	16:20:00	
2	OHP	BRC on CO28	BC Over load acted	Reset done in drive	17:00:00	17:10:00	
3	OHP	CO3B	Pull card bypassed in A shift	By pass removed	16:30:00	16:40:00	
4	OHP	CO32	B Phase failure and Power MCCB tripped and B phase not coming	Module changed from CO31 to CO32	16:00:00	19:20:00	May normalize in G shift
5	CHP	CC126	Not starting starting found Line PT2 auxiliary tripped and Incomer 2 breaker tripped	Relay reset done and breaker made on then ok	15:55:00	16:20:00	
6	CHP	SCR3 on CC38	BC not running found motor running but pulley not running	Informed to mechanical	16:00:00	16:10:00	
7	CHP	Cc112	Signal missing	LT done then ok	16:40:00	16:50:00	
8	CHP	SCR5 on CC32	LT not moving oT acted	Reset done	19:50:00	20:00:00	
9	CHP	SCR10 on CC105	BC not running found hard ware wiring problem common 110 v to glass relays fuse and BC FWD and BC RWD fuses blown	Wiring set properly and fuses replaced then ok	19:30:00	22:00:00	
10	CHP	CC52	OVER load acted	Reset done feeding conveyor stopped	17:55:00	18:40:00	6.00pm to 6.15pm
11	CHP	Cc132	Over load acted found jamming and	informed to operation	18:30:00	18:40:00	
12	CHP	CC54	Not healthy	pull card operated released then ok	18:00:00	18:05:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 15/07/2025

Incharge(s): V Balaji Naik

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	WT	SCO1A carriage	Olr acted 2 times	Reset done	15:40:00	15:45:00	3.49pm to 3.55pm
14	WT	OC1A belt	Belt drive olr tripped	Reset done	16:10:00	16:15:00	