



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 20/02/2026

Incharge(s): Nagendra Midde

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 31A BRS	GLASS FUSE BLOWN IN CJB	REPLACED	10:45:00	11:00:00	
2	OHP	WBR ON CO 25 SLEW	OLR ACTED	RESET	06:40:00	06:50:00	
3	CHP	SCR 2 ON CC 40 B/C	BELT SLIPPING DUE TO JAMMING	INFORMED TO OPRN	10:50:00 12:50:00	11:05:00 13:05:00	
4	CHP	SCR 7 ON CC 104 SLEW	B/W STUCK IN COAL	OPERATOR FAULT	12:30:00	12:50:00	
5	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	08:30:00	08:35:00	
6	CHP	CC 51A	OLR ACTED	RESET	07:05:00	07:10:00	
7	CHP	CC 130 TIS	MPCB TRIP DUE TO SHEET STUCK	REMOVED SHEET RESET THEN OK	10:15:00	10:30:00	
8	CHP	CC 14	CONTROL MCB TRIP	MADE IT ON	08:50:00	09:00:00	
9	CHP	CC 22 CD TRIP	MPCB TRIP	MADE IT ON	11:20:00	11:30:00	
10	WT	OP4	BEAKER TRIPPED	MADE IT ON	06:30:00	06:40:00	
11	IOSA	OC 37 A	MECHANICAL BRS ALIGNMENT PROBLEM	PROPERLY ADJUSTED THEN OK	12:00:00	12:30:00	