



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 24/08/2025

Shift: B

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO -31	ZSS INTERLOCK CAGE Struck	cage replaced then ok	17:40:00	18:00:00	
2	CHP	CC-26 TT AT CC-37	POSITION BIT MISSING	TT NOT PLACED PROPERLY ...INFORMED OPERATION	20:00:00	20:10:00	
3	CHP	CC37	BRS not getting reset	Sensor cleaning done then ok	15:05:00	15:20:00	
4	CHP	CC34	BRS kept in ckt as per operational requirement	In ckt	14:50:00	15:00:00	
5	CHP	CC47	BSS acted due to belt offcentering	Informed to operation after adjustment kept BSS kept in ckt	16:20:00	16:50:00	
6	CHP	SCR3 on CC40	Signal missing LT given forward	Then healthy	17:00:00	17:10:00	
7	CHP	SCR5 on CC32	LT not working found drive olr trip	Reset done	19:00:00	19:10:00	
8	CHP	CC32	Motor MPD over load trip	Reset done	18:50:00	19:00:00	
9	CHP	CC33(R)	BCnot working found ZSS cage inter lock problem	ZSS cage and proximity sensor replaced then ok	17:20:00	18:00:00	
10	CHP	SCR4 on CC31	Slew not working found found slew area coal jaming	Informed to operation	19:20:00	19:30:00	
11	CHP	SCR10 on Cc105	Reclaiming mode ZSS inter lock proximity sensor module side connection given	trail taken	20:00:00	20:10:00	
12	CHP	CC113A	Pull card acted	Reset done	14:50:00	15:00:00	
13	CHP	CC51	olr acted	Reset done	15:00:00	15:05:00	
14	CHP	CC51	MPD over load trip stopped feeding conveyor	Reset done	14:30:00	18:00:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 24/08/2025

Shift: B

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
15	CHP	CC54	olr trip 5 times	Reset done	14:15:00	14:50:00	