



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 05/12/2025

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 67	OLR ACTED	RESET	02:05:00	02:15:00	
2	OHP	WF 5	ZSS CAGE STUCKED	BYPASSED	23:30:00	23:40:00	
3	OHP	BRC ON CO 30 B/C	C/S ACTING DUE TO SCRAPPER PROBLEM	INFORMED TO MECH	23:05:00	23:25:00	
4	OHP	TBS ON CO 7A	RIGHT LUFF BREAK NOT RELEASING	MECH MADE IT OK	01:20:00	01:40:00	
5	OHP	CO 26	OLR ACTED	RESET	05:25:00	05:30:00	
6	OHP	TT4 ON CO7A	SENSOR PLATE NOT PLACED PROPERLY	PROPERLY PLACED THEN OK	04:50:00	05:05:00	
7	CHP	CC 54	OLR ACTED	RESET	22:30:00	05:30:00	25 TIMES
8	CHP	CC 51	FEEDING CONVEYOR OLR ACTED	RESET	23:00:00	05:00:00	10 TIMES
9	CHP	CC 53 T/T	F/G OLR ACTED	RESET	00:20:00	00:30:00	
10	CHP	SCR 8 LT	O/T ACTED	RELEASED	23:20:00	23:30:00	
11	CHP	SCR 6 ON CC 38 B/C	C/S ACTING DUE TO INSULATOR PROBLEM	BYPASSED	00:10:00	00:30:00	
12	CHP	SCR 3 ON CC 35	B/C OLR ACTED	RESET	02:15:00	02:25:00	
13	CHP	R1 ON CO 32	LUFF MPCB TRIP	MADE IT ON	02:55:00	03:05:00	