



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 10/06/2025

Shift: B

Incharge(s): Saurabh Kumar Yadav,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	VF 15 A	olr acted	reset	15:20:00	15:30:00	
2	OHP	BRC on Co 31	b/c olr acted	reset	19:40:00	19:50:00	
3	OHP	co 9	tripped in olr	reset it done	21:40:00	21:55:00	
4	CHP	CC 28	TT position on CC33 not coming,glass fuse blown in I/o rack	glass fuse replaced	16:15:00	16:25:00	
5	CHP	CC 131	tripped in olr	reset	19:55:00	20:00:00	3 times
6	CHP	CC 31 R1	b/c not running,yard conveyor zss interlock cage got stucked with material	cage made free than ok	20:45:00	21:00:00	
7	CHP	CC35 SCR2	LT not taking place,OT acted	OT released	21:00:00	21:10:00	
8	CHP	cc 105 scr 10	all drive not running,acb is in off	made it on	17:10:00	17:20:00	
9	CHP	CC 36 SCR1	luffing not working(wrong complaint),b/c chute jammed	informed operation	18:40:00	18:58:00	
10	WT	OP 6	D3 olr acted @ coupling	olr reset	19:30:00	19:40:00	