



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 13/02/2026

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLR ACTED	RESET	16:00:00	21:00:00	3 TIMES
2	OHP	CO 33M	OLR ACTED	RESET	21:10:00	21:15:00	
3	CHP	CC 117	OLR ACTED	RESET	16:15:00	16:30:00	
4	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	15:40:00	18:00:00	4 TIMES
5	CHP	CC 54	OLR ACTED	RESET	15:30:00	21:40:00	7 TIMES