



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 24/01/2026

Shift: B

Incharge(s): Nagendra Midde

| Sl No | Area | Equipment                       | Problem                       | Action            | From     | To       | Remarks |
|-------|------|---------------------------------|-------------------------------|-------------------|----------|----------|---------|
| 1     | OHP  | CO 25                           | OLR ACTED                     | RESET             | 18:00:00 | 20:20:00 | 4 TIMES |
| 2     | OHP  | CO 26                           | OLR ACTED                     | RESET             | 20:00:00 | 20:10:00 |         |
| 3     | OHP  | WBR ON<br>CO 6A LT              | SELECTOR SWITCH IN LOCAL MODE | CHANGED TO REMOTE | 19:20:00 | 19:35:00 |         |
| 4     | OHP  | CO 33M                          | OLR ACTED                     | RESET             | 21:30:00 | 21:35:00 |         |
| 5     | CHP  | CC 28                           | OLR ACTED                     | RESET             | 21:20:00 | 21:25:00 |         |
| 6     | CHP  | SCR 7 ON<br>CC 37<br>SLEW       | BREAK FAIL ALARM ACTED        | RESET             | 14:25:00 | 14:35:00 |         |
| 7     | CHP  | CC 54                           | OLR ACTED                     | RESET             | 15:30:00 | 15:40:00 |         |
| 8     | CHP  | CC 51                           | OLR ACTED                     | RESET             | 19:00:00 | 19:05:00 |         |
| 9     | CHP  | CC 51                           | FEEDING CONV MPD ACTED        | RESET             | 20:40:00 | 21:45:00 | 4 TIMES |
| 10    | CHP  | CC 116<br>BRS NOT R<br>ESETTING | RESET                         | THEN OK           | 20:05:00 | 20:20:00 |         |
| 11    | WT   | OP6                             | DRIVE 5 TRIPPED               | RESET             | 19:30:00 | 19:45:00 |         |