



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 22/07/2025

Shift: B

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS on CO-22	LT not taking place	Drive tripped.Reset done	16:00:00 17:30:00	16:15:00 17:45:00	
2	OHP	TBS on CO-23	LT not taking place	Power was in off condition.Power made on.	17:40:00	17:50:00	
3	OHP	CO-25	Reported not healthy	OLR acted due to load on belt.reset done	14:00:00 20:35:00 21:15:00	14:10:00 20:45:00 21:25:00	
4	OHP	TBS on CO-7A	Left luff not taking place	Drive tripped.reset done	20:35:00	20:45:00	
5	OHP	CO-111	Reported not healthy	Checked and found belt rubbing with pulley.Reset done	17:00:00	17:10:00	informed to operation
6	OHP	TT-1 on CO-14	Flap gate not working	OLR acted.reset done	19:25:00	19:30:00	
7	CHP	CC-105	Reported BRS not working	Checked and found working fine	16:40:00	16:50:00	Wrong complaint
8	CHP	CC-126	Hoist not working	MCCB tripped.Made on and tested okay	17:26:00	17:45:00	
9	CHP	CC-104 scr -9	B/C not healthy	Checked and found TUL chute jamming.	17:44:00	18:10:00	Informed to operation
10	CHP	CC-105 scr-7	Slew not taking place	Spider alarm high temperature.cooler fan cable got cut. cable outgoing removed from mcc panel.spider reset done and tested okay	18:43:00	19:15:00	cooler fan cable joint to be done
11	CHP	CC-40	BRS acted	BRS acted due to off centering.	19:40:00	19:50:00	informed to mechanical



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 22/07/2025

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	CHP	CC-104 scr-9	Lt not taking place	Checked and LT tested okay	20:54:00	21:05:00	wrong compliant
13	CHP	CC-54	Reported not healthy	OLR acted.reset done	14:45:00 18:50:00 21:30:00	14:50:00 18:55:00 21:35:00	