



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 02/09/2025

Shift: B

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-61	OLR ACTED (3TIMES)	RESET DONE	16:20:00	17:50:00	CONTACT OR AND O/G TERMINATION TIGHTENED NEAR MOTOR R PHASE REJOINTED
2	OHP	CO-84	OLR ACTED	OLR RESET DONE	21:30:00	21:40:00	
3	CHP	cc-40 scr-3	LT NOT TAKING PLACE	PCRD O/T LIMIT ACTED .O/T RELEASED THAN LT OK	14:20:00	14:30:00	
4	CHP	CC-39 SCR-7	REPORTED SLEW NOT WORKING	CHECKED AND FOUND SPIDER ALARM BREAK FAIL THAN SPIDER RESET SLEW OK	16:10:00	16:20:00	
5	CHP	CC-32 SCR-5	REPORTED SLEW NOT WORKING	CHECKED AND FOUND SLEW 30 LIMIT NOT COMING THAN 30 LIMIT BYPASS THAN SLEW OK	16:30:00	16:40:00	
6	CHP	CC-36 SCR-1	LUFF NOT WORKING	CHECKED AND FOUND MPCB TRIP .MPCB RESET	18:45:00	19:00:00	
7	CHP	CC-28 B/D	OLR ACTED	OLR RESET DONE	20:20:00	20:30:00	
8	CHP	CC-21C/D	OLR ACTED	OLR RESET DONE	20:40:00	20:50:00	
9	CHP	CC-131	REPORTED NOT HEALTHY	CHECKED AND FOUND OLR ACTED OLR RESET DONE	14:30:00	14:35:00	
10	CHP	CC-114	OLR ACTED	OLR RESET DONE	16:30:00	16:40:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 02/09/2025

Incharge(s): Amit Roy, K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
11	CHP	CC117	OLR ACTED	OLR RESET DONE	17:55:00	18:10:00	
12	CHP	CC-52	STOPPING ON ZSS	CHECKED AND FOUND NO ELECTRICAL PROBLEM DUE TO BELT SNAP	19:55:00	20:10:00	INFORM TO MECHANICAL
13	WT	CP-4	NOT MOVE	CHECKED AND FOUND HEALTHY RELAY PROBLEM RELAY REPLACED WITH NEW RELAY THAN OK	15:45:00	16:30:00	
14	WT	OT-5	DRIVE-1 TRIP (F-8 FAULT)	DRIVE RESET DONE	21:00:00 21:30:00	21:10:00 21:40:00	