



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 28/01/2026

Area: WT

Equipment	Job
CP 3 jobs	R H S , drive panel to D B U and D B U TO D B R cable laying done
CP 3 jobs	All motors gland plates fixing and termination done
CP 1	Top pad and C clamp replaced and trolley line inspection done, clearance given
CP 2 and 4	After rake maintenance done
OP 1	D6 Motor placed ,alignment ,termination and testing done (5 motors in ckt)
OP 1 to 5	after rake maintenance done