



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 31/07/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 41A	not healthy,BRS acted	reset	01:20:00	01:35:00	operation problem
2	OHP	CR1A	zss acted,probe cable damaged due to stone	cable re jointed	00:30:00	00:40:00	
3	OHP	WOBR on co 25	slew not working,slew drive tripped in overload	reset	01:45:00	01:55:00	
4	OHP	CO 33M	B/W 2 not rotating	fault reset done than ok	23:45:00	23:55:00	
5	OHP	CO 84	olr acted	reset	04:30:00	04:35:00	
6	OHP	TT 4	Lt tripped 2 times,mpcb tripped	made it on	00:50:00	00:55:00	
7	OHP	CO 22	not healthy,emergency in red,in cjb control cable loose connection	cable tightened	02:00:00	02:35:00	
8	OHP	TBS on CO 22	LT not taking place,BRAKE too much tight	informed operation and mech,for brake adjustment	02:35:00	02:50:00	
9	OHP	BRC on CO 30	LT not taking place ,acb is in off	acb made on	04:00:00	04:20:00	
10	OHP	CO 7	red not healthy,IT acted	reset	05:05:00	05:10:00	
11	CHP	CC 111	not healthy,PC acted	PC released	22:50:00	23:00:00	
12	CHP	CC 34 SCR2	LT not working,OT acted	OT released	00:35:00	00:45:00	
13	CHP	CC 38 S1	LT not working,drive tripped in overload	reset	03:00:00	03:10:00	
14	CHP	CC 54	olr acted	reset	05:45:00	05:50:00	
15	CHP	CC 29	OLR acted 3 times due to material	reset	00:45:00	00:50:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 31/07/2025

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
16	CHP	CC 29 TT	not moving,one phase missing,pcrd cable is in full tension ,too much material	100 meter temporary cable connected and given power supply and TT movement done	03:30:00	05:00:00	TT position on 32
17	WT	CO 3(B)	MPCB TRIPPED due to overload	reset	05:00:00	05:10:00	
18	WT	CC 2(b)	mpcb tripped	reset	04:45:00	04:50:00	