



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 12/08/2025

Area: CHP

Equipment	Job
CC-131	4 NO'S BELT SWAY SWITCHES KEPT IN CIRCUIT
CC-51 Tunnel	FG-112 area LDB ppm done and defective MCB replaced
Misc	5 no's 50w leds prepared and tested
SCR-7,SCR-5	Instrumentation switches ppm done
Misc	CM-18 panel preparation is under progress
CC-32	Running inspection done and defects rectified
cc-32,scr-5,cc-105,scr-7	ppm done