



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 13/01/2026

Shift: A

Incharge(s): K SANKARA RAO

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------|--|----------------------------------|----------------------|----------------------|---------|
| 1 | OHP | CO-12 | REPORTED NOT HEALTHY FOUND POWER MCCB AUX CONTACT PROBLEM | AUX BLOCK PROPERLY FIXED THAN OK | 08:10:00 | 08:20:00 | |
| 2 | OHP | TBS ON CO-5A | REPORTED LT NOT TAKING PLACE FOUND CONTROL MCB OFF CONDITION | MCB MADE ON THAN OK | 10:30:00 | 10:40:00 | |
| 3 | OHP | BRC ON CO-31 | B/W-1 OLR ACTED | RESET DONE | 10:50:00 | 11:00:00 | |
| 4 | CHP | CC-51 | TRIPPED ON MPD (10 TIMES) FEEDING CONVEYOR STOP | RESET DONE | 07:00:00 | 13:20:00 | |
| 5 | CHP | CC-51 | TRIPPED ON OLR | RESET DONE | 13:00:00 | 13:10:00 | |
| 6 | CHP | CC-55 | REPORTED NOT HEALTHY FOUND P/C ACTED | PULL CHORD BYPASSED THAN OK | 11:00:00 | 11:20:00 | |
| 7 | CHP | CC-103 | REPORTED BRS NOT HEALTHY | BRS SUPPLY RE-CYCLED THAN OK | 06:40:00 | 06:50:00 | |
| 8 | CHP | TT ON CC-102 | REPORTED C/S NOT HEALTHY LOOSE AT I/O RACK | TIGHTENED THAN OK | 11:20:00 | 11:40:00 | |
| 9 | CHP | CC-29 | TRIPPED ON OLR | RESET DONE | 13:40:00 | 13:50:00 | |
| 10 | CHP | CC-47 | DRIVE TRIP | RESET DONE | 07:30:00 | 07:40:00 | |
| 11 | CHP | CC-35 SCR-3 | B/C TRIP ON OLR | RESET DONE | 08:10:00 | 08:20:00 | |
| 12 | CHP | CC-213 | OLR ACTED | RESET DONE | 08:30:00 | 08:40:00 | |
| 13 | CHP | CC-45 | OLR ACTED(2TIMES) | RESET DONE | 11:25:00 11:55:00 | 11:30:00 12:00:00 | |
| 14 | WT | AF-4 | DRIVE TRIP FAULT CODE SPEED VARIATION | RESET DONE THAN OK | 07:00:00 | 07:10:00 | |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 13/01/2026

Incharge(s): K SANKARA RAO

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|-----------------------------------|-----------------------------|----------|----------|---------|
| 15 | WT | OT-2 | DRIVE-2 PGF-1 FAULT TRIP (7TIMES) | RESET DONE | 06:30:00 | 13:25:00 | |
| 16 | WT | OP-5 | WAGON SENSOR ACTED FREQUENTLY | DISCONNECTED THAN OK | 10:15:00 | 10:40:00 | |
| 17 | IOSA | TBS ON OC-13A | COMMUNICATION PROBLEM | PLC POWER RE-CYCLED THAN OK | 07:20:00 | 07:40:00 | |